File E28476 March 04, 1977

REPORT

On

COMPONENT - CONNECTORS FOR USE IN DATA, SIGNAL, CONTROL AND POWER APPLICATIONS

TYCO Electronics Corp Middletown, PA

Copyright © 1977 Underwriters Laboratories Inc.

Underwriters Laboratories Inc. authorizes the above named company to reproduce this Report only for purposes as described in the Conclusion. The Report should be reproduced in its entirety; however to protect confidential product information, the Construction Details Descriptive pages may be excluded.

File E28476	Vol. 1	Sec. 31	Page 1	Issued:	1977-03-04
	Vol. 20	Sec. 9		Revised:	2022-04-06
	Vol. 52	Sec. 3			
	Vol. 132	Sec. 5			
	Vol. 147	Sec. 4			
		and Report			

DESCRIPTION

PRODUCT COVERED:

Hermetic Cluster Block series; Part Nos. 360051-1, 360052-1, 360033-1, 360050-1,521078-1, 1217263-1, 520805-1, 520866-1, 880631-5, 1380145-1, and 1380145-2 for use in hermetic compressors rated 120-240 V ac, 60 Hz, single phase.

Hermetic Cluster Block series; Cat. Nos. 1217181-1, 1217186-1,1217187-1, 521572-1, 521573-1, 521776-1, 521949-1, 1217200-1, 1217261-1, 1217262-1,1217263-1, 1375735-1, 520995-1, 737110-1, 1604563-1, 521674-1, 521674-2, 521571-1, 521754-1, 1969162-1, 521481-1, 2232326-1, -2, 2232327-1, -2, 1969689-1, 1969689-2, 2825316-1, 284406-3, 284406-1.

USR and CNR, Hermetic Cluster Block series, Cat. No 235280-1, 235280-4.

USR and CNR, Hermetic Cluster Block series, Housing Cat. Nos. 2232326-1 , 2232326-2, 2232327-1, 2232327-2 with contact PN 2825745-1.

USR, Hermetic Cluster Block series, Housing PN 235280-1, -4 mating with contact PN 62131-5, -6. Housing PN 235280-1, -4 mating with contact PN 2178453-1. Housing PN 284406-1, -3 mating with contact PN 2178453-1. Housing 2825312-1 mating with contact PN 2825313-1.

USR, Hermetic Cluster Block series, Housing PN 284406-1 mating with this terminal 62131-3, 284633-1.

GENERAL:

Catalog number 235280-4 replaces catalog number 0-235280-4. All references below are to the "old" catalog number.

Part No. 360033-1 consists of molded body Part No. 360033 with receptacle connectors Part No. 62131-1, -2 or -3, a No. 16 AWG lead wire.

Part No. 360050-1 or 1217263-1 consists of molded body Part No. 360050 with receptacle connectors Part No. 62131-1, -2 or -3, a No. 16 or 18 AWG lead wire.

Part No. 360051-1 consists of molded body Part No. 360051 with receptacle connector Part No. 62243-1, -2, -3, -4, 62244-1, -2, -3 or -4. Receptacle connector Part No. 62243-1, -2, -3 or -4 employs No. 12 or 14 AWG wire. Receptacle connector Part No. 62244-1, -2, -3 or -4 employs, No. 16 or 18 AWG wire.

File	E28476	Vol. 1	Sec.	31	Page	1-1	Issued:	1977-03-04	
		Vol.	20	Sec.	9			New:	2022-04-06
		Vol.	52	Sec.	3				
		Vol.	132	Sec.	5				
		Vol.	147	Sec.	4				
			ā	and Re	eport				

Electrical Contact Series 63453, 63454, 63455, 63906, 63907, 63908, 1217670, 1217671, 1217672, 1742964, 174298 are for use with magnet wire.

The lead wires are provided by the end-use manufacturer.

The molded bodies and the receptacle connectors are assembled by the end-use manufacturer. Each component is shipped in separate cartons.

Part Nos. 521674-1 and 521674-2 are similar to Part No. 1217200-1 except the former employ shorter housing dimensions.

Part Nos. 1742096-1, 1742116-1 and 1742117-1 are similar to Part Nos. 1217174-1, 1217172-1 and 1217173-1 respectively except the insulation support crimp has been removed.

File E28476	Vol. 1	Sec. 31	Page 1A	Issued:	1977-03-04
	Vol. 20	Sec. 9	-	Revised:	2020-06-23
	Vol. 52	Sec. 3			
	Vol. 132	Sec. 5			
	Vol. 147	Sec. 4			
		and Report			

Part No. 521571-1 is similar to Part No. 1217181-1 except the former is provided with keyhole type pin entry holes.

Part No. 521481-1 is similar to Part No. 1217200-1 except the former is provided with keyhole type pin entry holes.

Part No. 521754-1 is similar to Part Nos. 521674-1 and 521674-2 except the former is provided with a decreased base skirt height and an increase in chamfer at the front corners.

Part No. 1380145-1, -2 consists of molded body Part No. 1380145 with receptacle connectors Part No. 62131-x, on 16 or 18 AWG lead wire.

Part No. 880631-5 consists of molded body Part No. 880631 with receptacle connectors Part No. 62131-3, on 16 or 18 AWG lead wire.

Contact Cat. Nos. 63906, 63907, 63908, 1217670, 1217671, and 1217672 are similar to contacts Cat. Nos. 63455, 63454, 1217172, 1217172, 1217174, and 63455 respectively, but with larger cross-section mating surface.

Housing Cat. No. 284406-3 is intended to be used solely with contact PN 62131-3. No electrical ratings.

Housing Cat. No. 284406-3 is intended to be used solely with contact PN 284633-1. Combination only has a voltage rating.

Housing Cat. No. 235280-1, 0-235280-4 is intended to be used solely with contact PN 62131-3. Combination only has a voltage rating.

Housing 235280-1, -4 are intended to be used solely with contact PN 62131-5, -6. Combination only has a voltage rating.

Housing 235280-1, -4 are intended to be used solely with contact PN 2178453-1. Combination only has a voltage rating.

Housing 284406-1, -3 are intended to be used solely with contact PN 2178453-1. Combination only has a voltage rating.

Housing Cat. No. 284406-1 is intended to be used solely with contact PN 284633-1. Combination only has a voltage rating.

Housing Cat. No. 284406-1 is intended to be used solely with contact PN $\,$ 62131-3. Combination only has a voltage rating.

File E28476

Vol.	1	Sec. 31
Vol.	20	Sec. 9
Vol.	52	Sec. 3
Vol.	132	Sec. 5
Vol.	147	Sec. 4
		and Report

Page 1	1B
--------	----

1977-03-04
2008-08-01

Housings / Receptacles UL file E28476					
Products for H	eaders having				
Z.Z9mm[.090"] Dia. Pins					
Housing #	Receptacle #*				
360033-()	62131-()				
360050-()	63448-()				
521078-()	1217264-()				
1217262-()					
1217263-()					
*Any receptacle listed in	this group can be used				
with any housin	in the group.				
Dreducto for H					
3 18mm[12	s"1 Dia Pins				
Housing #	Recentacle #**				
360051-()	62243-()				
360052-()	62244-()				
520995-()	63453-()				
521481-()	63454-()				
521571-()	63455-()				
521572-()	63906-()				
521573-()	63907-()				
521674-()	63908-()				
521754-()	1217172-()				
521776-()	1217173-()				
521949-()	1217174-()				
1217181-()	1217175-()				
1217186-()	1217176-()				
1217187-()	1217670-()				
1217200-()	1217671-()				
1217261-()	1217672-()				
1969162-()	1742096-()				
	1742116-()				
	1742117-()				
1	1742657-()				
**Any receptacle listed	d in this group can be				
used with any hou	sing in the group.				
used with any nou	ang malo group.				

File E28476	Vol. 1	Sec. 31	Page 1B1	Issued:	1977-03-04
	Vol. 20	Sec. 9	-	Revised:	2022-04-06
	Vol. 52	Sec. 3			
	Vol. 132	Sec. 5			
	Vol. 147	Sec. 4			
		and Report			

RATINGS:

Cat. Nos.		Voltage Vac/Vdc		Ampere (A)	Conductor Sizes, AWG Cu
2232326-1, -2, 2232327-1, -2		300		-	18 - 16 AWG str
1380145-1, -2		300		-	18 - 16 AWG str
880631-5		300		-	18 - 16 AWG str
520995-1		600 (1)			
284406-3 housing with this terminal 284633-1		240			
235280-1 housing with this terminal 62131-3		300			
0-235280-4 housing with this terminal 62131-3		300			
235280-1, -4 housing with this terminal 62131-5, -6		300			
235280-1, -4 housing with this terminal 2178453-1		300			
284406-1,-3 housing with this terminal 2178453-1		240			
284406-1 housing with this terminal 62131-3, 284633-1		240			
Housing Cat. Nos. 2232326-1 ,				5	20 AWG str
2232326-2, 2232327-1, 2232327-2 with contact PN 2825745-1		300		7	18 AWG str
Housing 2825312-1 mating with				6	18 AWG str
contact PN 2825313-1		300		8	16 AWG str
CONTACT PN 2023313-1				10	14 AWG str

Note (1): 600VAC at 180Hz

File E28476	Vol. 1	Sec. 31	Page 1C	Issued:	1977-03-04
	Vol. 20	Sec. 9		Revised:	2022-04-06
	Vol. 52	Sec. 3			
	Vol. 132	Sec. 5			
	Vol. 147	Sec. 4			
		and Report			

USR - Products designated USR have been evaluated to the United States Standards as referenced in the Test Record.

CNR - Products designated CNR have been evaluated to the Canadian Standards as referenced in the Test Record.

ENGINEERING CONSIDERATIONS (NOT FOR UL REPRESENTATIVE USE):

These are components intended for use on refrigeration equipment where the acceptability of the combination has been determined by Underwriters Laboratories Inc.

The following should be determined in judging the acceptability of the combination.

- 1. These devices are not suitable for interrupting the flow of current by connecting or disconnecting the mating connector.
- *2. Unless otherwise specified, these devices have not been subjected to the Temperature test and as a result do not have an assigned current rating. The device's current carrying capability is to be reviewed in the end-use by measuring temperatures on the connector housing and/or terminals when current is flowing through the connector under conditions of normal use.

2A. The following devices have been subjected to the Temperature test with the rated currents and maximum temperature rise and recorded temperature (adjusted to 25° C ambient) values tabulated below:

		Maximum Temperature °C		
Series	Current, A	Rise	Recorded Temperature	
Housing 2825312-1 with contact PN 2825313-1 and mating connector Hermitic Pin	10	20.6	45.6	
Housing 2825312-1 with contact PN 2825313-1 and mating connector Hermitic Pin	8	15.6	40.6	
Housing 2825312-1 with contact PN 2825313-1 and mating connector Hermitic Pin	6	11.5	36.5	
Housing 2232326-1 with contact PN 2825745-1 and mating connector Hermitic Pin	7	15.7	40.7	
Housing 2232326-1 with contact PN 2825745-1 and mating connector Hermitic Pin	5	12.8	37.8	

File	E28476	Vol.	1	Sec.	31	Page	1C1	Issued:	1977-03-04
		Vol.	20	Sec.	9			New:	2022-04-06
		Vol.	52	Sec.	3				
		Vol.	132	Sec.	5				
		Vol.	147	Sec.	4				
				and Rep	port				

- 3. The lead wire material which is supplied by the end manufacturer is suitable for the end-use application.
- 4. The lead wires are suitably attached to the receptacle connector.
- 5. The compressor used with these connectors will operate below the following VA ratings as determined by requirements of the applicable Standard:

Part Nos.	Compressor Rating
360033-1,360050-1, 1217263-1	1200 VA
360051-1 with contact 62243-x	3000 VA
360051-1 with contact 62244-x	1800 VA
360052-1 with contact 62324	3000 VA
360052-1 with contact 62325	1800 VA
880631-5 with contact 62131-x	1600 VA

- 6. The connectors are intended for use inside compressors that employ Refrigerant Type R12, R22, R500 R502, R410A, R407C, and R134A. Suitability for use with these refrigerants shall be an end use consideration.
- 7. Fusite terminal connectors Part No. 360051-1 and 360052-1 are for use with terminals provided with a 0.125 in dia electrode and Part No. 360033-1 and 360050-1 are for use with terminals provided with 0.090 in diameter electrodes.

File E28476	Vol. 1	Sec. 31	Page 1D	Issued:	1977-03-04
	Vol. 20	Sec. 9		Revised:	2023-01-04
	Vol. 52	Sec. 3			
	Vol. 132	Sec. 5			
	Vol. 147	Sec. 4			
		and Report			

- Part Nos. 521571-1 and 521754-1 may be used at potentials not exceeding 600 V based on the minimum 3.2mm (1/8 inch) spacings required by UL 1977.
- 9. These devices employ insulating materials with properties as tabulated below at the minimum thickness employed in the connector housing, the suitability of the insulating materials based on the documented values shall be determined in the end-use application. Please note the values specified in the table when multiple materials are indicated represent the minimum values for the group of materials.

Cat. Nos.	Insulating Material (#)	Measured Minimum Thickness	Flame Class	HWI	HAI	RTI Elec	Max Operating Temp, °C
	A	1.5 mm	0	0	0	140	120
	В	1.5 mm	HB	3	0	120	120
	С	1.5 mm	HB	4	0	120	120
	D	1.5 mm	HB	4	0	140	120
2232326-1, 2232327-1	E	0.85 mm	V-0	3	0	120	120
2232326-2, 2232327-2; 2825312-1	F	0.85 mm	V-0	1	0	140	140
284406-3 235280-1	G	0.9 mm	HB	3	1	140	140
284406-1	J	0.9 mm	HB	_	_	75	75
0-235280-4	I	0.9 mm	HB	_	_	140	140
1380145-1	E	0.70 mm	V-0	-	-	120	120
1380145-2	В	0.70 mm	-	_	_	120	120
880631-5	В	0.70 mm	-	-	-	120	120
1969689-1, 1969689-2	В	0.70mm				120	120
2825316-1	Н	0.4mm	V0	0	0	130	130
	K	0.4mm	V0	0	0	130	130
2825312-1	L	0.85 mm	V0	0	0	130	130
2232326-2, 2232327-2	L	0.85 mm	V0	0	0	130	130

(#) - Code for Insulating Body Material.

File	E28476	Vol. Vol. Vol. Vol. Vol.	1 20 52 132 147	Sec. Sec. Sec. Sec.	31 9 3 5 4	Page	1D1	Issued: New:	1977-03-04 2023-01-04
Д	Тусо Raw Ma	terial	; L # 157	and Re 3547	port				
	<pre>1. Dielectric strength (kV/mm): 23 2. CTI: 3</pre>								
в.	Тусо Raw Ma	terial	L # 272	55					
	4 - 1			1 /					

1. Dielectric strength (kV/mm): 23
2. CTI: 0

File	E28476	Vol. 1 Vol. 20 Vol. 52 Vol. 132 Vol. 147	Sec. 31 Sec. 9 Sec. 3 Sec. 5 Sec. 4 and Repor	P	age 1E	Issued: Revised:	1977-03-04 2023-01-04				
с.	Tyco Raw Material # 18390										
	1. Dielectr 2. CTI: 0	ic strength	(kV/mm):	26							
л	Тусо Raw Ma	Tyco Raw Material # 703378									
<i>D</i> .	<pre>1. Dielectric strength (kV/mm): 29 2. CTI: 0</pre>										
r.	Тусо Raw Ma	Tyco Raw Material # 26864-1									
с.	<pre>1. Dielectric strength (kV/mm): 22 2. CTI: 3</pre>										
F.	Тусо Raw Ma	terial # 21	36325-1								
	1. Dielectr 2. CTI: 1	ic strength	(kV/mm):	11							
G.	Tyco Raw Ma 1. Dielectr 2. CTI: 1	Tyco Raw Material # 705199-1 1. Dielectric strength (kV/mm): 42 2. CTI: 1									
н.	Tyco Raw Ma 1. Dielectr 2. CTI: 1	Tyco Raw Material # 2136488 1. Dielectric strength (kV/mm): 8 2. CTI: 1									
I.	Tyco Raw Ma 1. Dielectr 2. CTI:	terial # 21 ic strength 0	36318-1 (kV/mm):	28							
J.	Tyco Raw Material # 704923-1 1. Dielectric strength (kV/mm): - 2. CTI: -										
К.	Tyco Raw Ma 1. Dielectr 2. CTI: 1	terial # 70 ic strength	5999-1 (kV/mm):	8							
*L.	Tyco Raw M 1. Dielectr 2. CTI: 1	aterial # 2 ic strength	36919 (kV/mm):	18							

File E28476	Vol. 1	Sec. 31	Page 1F	Issued:	1977-03-04
	Vol. 20	Sec. 9	2	New:	2020-06-23
	Vol. 52	Sec. 3			
	Vol. 132	Sec. 5			
	Vol. 147	Sec. 4			
		and Report			

- 10. Dielectric Voltage-withstand testing has been conducted on Cat. Nos. 2232326-1, -2, 2232327-1, -2, 1380145-1, -2, 880631-5, 235280-1 housing with this terminal 62131-3, 0-235280-4 housing with this terminal 62131-3 between adjacent poles at a potential of 1600 V. Dielectric Voltage-withstand testing has been conducted on 235280-1, -4 housing with this terminal 62131-5, -6 between adjacent poles at a potential of 1600 V. Dielectric Voltage-withstand testing has been conducted on 235280-1, -4 housing with this terminal 2178453-1 between adjacent poles at a potential of 1600 V. Dielectric Voltage-withstand testing has been conducted on 284406-1,-3 housing with this terminal 2178453-1 between adjacent poles at a potential of 1480 V. Dielectric Voltage-withstand testing has been conducted on 284406-1 housing with this terminal 62131-3 between adjacent poles at a potential of 1480 V.
- 11. The maximum volt-ampere rating should be judged in the end-use application.