SAFETY ORGANIZATION(S):

THIS FILTER HAS BEEN FORMALLY RECOGNIZED, CERTIFIED OR APPROVED BY THE LISTED AGENCY. THEREFORE, ALL TEST/REQUIREMENTS SPECIFIED IN THE LATEST REVISION OF THE FOLLOWING AGENCY STANDARDS HAVE BEEN MET:

RECOGNIZED CSA CERTIFIED VDE APPROVED SEV APPROVED

UL 1283 C5A 22.2, NO.0,0.4,8 VDE 565-3 SEV 1055/TP1977/5.1.1

OPERATING SPECIFICATIONS:

3 AMP, 120/250 VAC 3 AMP./40°C, 250 VAC LINE VOLTAGE/CURRENT:

LINE FREQUENCY: 50-60Hz
MAX. CASE RISE & RATED CURRENT: 40°C
MAX. LEAKAGE CURRENT, EACH: .2

.25 mA AT 120V 60Hz .4 mA at 250V 50Hz LINE TO GROUND:

OPERATING AMBIENT TEMP. RANGE: -10°C TO +40°C P RATED CURRENT, I.

IN AN AMBIENT, To, HIGHER THAN 40°C, THE MAXIMUM OPERATING CURRENT, Io, IS AS FOLLOWS:

 $I_0 = I_r - \sqrt{\frac{85 - T_0}{45}}$

RELIABILITY SPECIFICATIONS:

STORAGE TEMPERATURE. -40°C TO +85°C
HUMIDITY: 21 DAYS 9 40°C 95% RH
CURRENT OVERLOAD TEST. 6 TIMES RATED CURRENT FOR 8 SECONDS

TEST SPECIFICATIONS:

INDUCTANCE: 14.12 mH NOMINAL CAPACITANCE: (MEASURED 0 1 KHz, 0.25VAC MAX., 25°C±1°C) LINE TO GROUND: .0056µF ±20% LINE TO LINE: .811µF ±20% DISCHARGE RESISTOR: 330KΩ


LINE/GROUND AND LINE/LINE INSULATION RESISTANCE: 6000Mg (MIN) AT 100VDC, 20°C AND 50% RH.


RECOMMENDED RECEIVING INSPECTION HIPOT:

LINES TO GROUND: LINE TO LINE: 2250 VDC FOR 1 MINUTE 1450 VDC FOR 1 MINUTE

FILTER APPROVAL:

THE BEST WAY TO SELECT AND QUALIFY A FILTER IS FOR YOUR ENGINEERING TO TEST THE UNIT IN YOUR EQUIPMENT.





UNLESS OTHERWISE SPECIFIED, TOLERANCE TO BE ±.025 MATERIAL & FINISH: AS SUPPLIED

This document is proprietary to CORCOM INC. and is not to be reproduced nor used for manufacturing purposes except on CORCOM'S prior written consent.



POWER LINE FILTER CATALOG NO.

DATE: 12-13-94 APPRVO MAC

3EP3.08

ECN#11131 CAD NO.