



Certificate of Compliance

Certificate: 1292133 (LR 7189-298)

Master Contract: 164196

Project: 2683429

Date Issued: December 3, 2013

Issued to: Tyco Electronics Corporation

2901 Fulling Mill Rd
Mail Stop 140-08
Middletown, PA 17057-3163
USA
Attention: Ms. Kathy Long

The products listed below are eligible to bear the CSA Mark shown



Mike W. Gryschuk

Issued by: Mike W. Gryschuk, C.E.T.

PRODUCTS

CLASS 6233 01 - RECEPTACLES - Attachment Plug Type and Plugs

Special-use "0.093 Commercial Pin and Socket" connectors, Series 3504XX, 770XXX, 794XXX, 1586XXX, rated 15A max, 600V.

APPLICABLE REQUIREMENTS

CSA Std. C22.2 No. 182.3-M1987, 1st Ed - Special Use Attachment Plugs, Receptacles, and Connectors



Descriptive Report and Test Results

MASTER CONTRACT: 164196

REPORT: 1292133

PROJECT: 2683429

Edition 1: June 17, 1991; Application No LR 7189-298 - Toronto
Issued by Richard Carter, P. Eng; Reviewed by George Aldridge, C.E.T.

Edition 6: February 14, 2002; Project 1292133 - Toronto
Issued by Mike W. Gryschuk, C.E.T.

Report Reissued
Figures Added: Figs 96 to 97

Edition 10: July 5, 2010; Project 2325941 - Toronto
Issued by Mike W. Gryschuk, C.E.T.

Report Reissued
Figures Added: Figs 100 to 103

Edition 11: December 3, 2013; Project 2683429 - Toronto
Issued by Mike W. Gryschuk, C.E.T.

Report Reissued
Figures Replaced: Figs 1 to 95
Figures Added: Figs 104 to 106
Attachments Deleted: Photo

Contents: Certificate of Compliance - Pages 1 to 1
Supplement to Certificate of Compliance - Pages 1 to 1
Description and Tests - Pages 1 to 8
Figures - Figs 1 to 106 (in Documentum)

PRODUCTS

CLASS 6233 01 - RECEPTACLES - Attachment Plug Type and Plugs

Special-use "0.093 Commercial Pin and Socket" connectors Series 3504XX, 770XXX, 794XXX, 1586XXX, rated 15A max, 600V.

APPLICABLE REQUIREMENTS

CSA Std. C22.2 No. 182.3-M1987, 1st Ed - Special Use Attachment Plugs, Receptacles, and Connectors

This report shall not be reproduced, except in full, without the approval of CSA Group.

178 Rexdale Boulevard, Toronto, ON, Canada M9W 1R3
Telephone: 416.747.4000 1.800.463.6727 Fax: 416.747.4149 www.csagroup.org

MARKINGS

The manufacturer is required to apply the following markings:

- Products shall be marked with the markings specified by the particular product standard.
- Products certified for Canada shall have all Caution and Warning markings in both English and French.

Additional bilingual markings not covered by the product standard(s) may be required by the Authorities Having Jurisdiction. It is the responsibility of the manufacturer to provide and apply these additional markings, where applicable, in accordance with the requirements of those authorities.

The Submitter's name/tradename/trademark (ie. "AMP" or "Tyco"), the CSA Mark are marked on each connector. The Submitter's identification, the CSA Mark, the Cat No, the electrical rating, the wire size range and the following (or equivalent) wording: "CAUTION: NOT FOR INTERRUPTING CURRENT" and "ATTENTION: NE PAS EMPLOYER POUR LA RUPTURE DU COURANT" appear on each carton.

ALTERATIONS

See "Markings" above.

FACTORY TESTS

None.

SPECIAL INSTRUCTIONS FOR FIELD SERVICES

None.

COMPONENT SPECIAL PICKUP

None.