



TCFS-**-***-3**-100CH

a) Part as supplied.



b) Part after unrestricted recovery.



KITS TO INCLUDE CLEANING TISSUE, 1 PIECE 100 GRIT EMERY CLOTH & 1 PIECE OF ATUM.
KIT TO BE USED IN CONJUNCTION WITH TCFS INSTALLATION PROCEDURE.

Dimensions (in millimetres)

PART No.	A	J	M	A/F	L	P	J0	
	min	min	max	THREAD	Nut	NOM	Ref	
		a	b			b	b	
TCFS-12	7.4	7	5.0	M12 x 1.5	17	24	50	15
TCFS-16	10.1	9	6.0	M16 x 1.5	22	29	65	17
TCFS-20	14.1	11	7.2	M20 x 1.5	27	34	77	20
TCFS-24	19.1	17	8.5	M24 x 1.5	30	38	90	25
TCFS-30	24.1	21	10.0	M30 x 1.5	36	47	115	30
TCFS-36	30.1	29	15.8	M36 x 1.5	41	52	140	30

Copyright (!)
Urheberrechte

The copyright in this drawing is the property of Raychem Ltd. The drawing is issued on condition that it is not copied, reproduced or disclosed to a third party, either in whole or in part without the prior written consent of Raychem Ltd.

Drawn A.LILLEY. Checked *[Signature]* Issue 1 Date December 1995 Conforms to ISO Recommendations
3rd Angle Projection
Not to Scale

Approval
Design


AAPS

MKTG.

[Signature]

Q.A.

[Signature]




Iss.	Date	E.C.R. No.	Details of Change

Material

(-100) ZERO HALOGEN

Part Numbering System.

TCFS-**-***-3**-100CH



Raychem
 Thermofit Division, Europe,
 Swindon, Wiltshire, England.
 Telephone: (0793) 528171 Fax: 573923