



产品认证证书

证书编号: CQC16002142753

发证日期: 2024年03月07日
有效期至: 2029年03月06日

委托人名称 泰科电子(深圳)有限公司
及注册地址 深圳市宝安区石岩街道泰科电子科技园

制造商名称 泰科电子(深圳)有限公司
及注册地址 深圳市宝安区石岩街道泰科电子科技园

生产企业名称 泰科电子(深圳)有限公司
及生产地址 深圳市宝安区石岩街道泰科电子科技园

产品名称和系列、规格、型号 继电器
T92 系列 触点负载: 常开型: 30A 277VAC/30VDC; 转换型: 30A 277VAC/30VDC(常开)、3A 277VAC/30VDC(常闭); 常开型: 30A 250VAC(X 触点系列); 线圈: 12VAC、24VAC、48VAC、110VAC、110VAC/120VAC、208VAC、220VAC/240VAC、250VAC/277VAC; 3.5VA/4.0VA; 电气寿命: 20000 周期(277VAC)、10000 周期(30VDC)、100000 周期(30A 250VAC/X 触点系列); 机械寿命: 200000 周期; 环境温度: -40°C~65°C; -40°C~25°C(X 触点系列); RTII、RTIII

产品标准和技术要求 GB/T 21711.1-2023

认证模式 产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC11-462155-2010 认证规则的要求, 特发此证。
本证书为变更证书, 证书首次颁发日期: 2016年06月15日
证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

可通过扫描下方二维码或登录国家认监委网站 (www.cnca.gov.cn) 查验证书信息



签发:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE





CERTIFICATE OF PRODUCT CERTIFICATION

CERTIFICATE NO.: CQC16002142753

Valid from: Mar.07,2024

Valid until:Mar.06,2029

NAME AND REGISTERED ADDRESS OF THE APPLICANT Tyco Electronics (shenzhen) Co., Ltd
Tyco Electronics Technology Park,Shiyan Town,Baoan District,Shenzhen, Guangdong, P.R.China

NAME AND REGISTERED ADDRESS OF THE MANUFACTURER Tyco Electronics (shenzhen) Co., Ltd
Tyco Electronics Technology Park,Shiyan Town,Baoan District,Shenzhen, Guangdong, P.R.China

NAME AND LOCATION OF THE FACTORY Tyco Electronics (shenzhen) Co., Ltd
Tyco Electronics Technology Park,Shiyan Town,Baoan District,Shenzhen, Guangdong, P.R.China

PRODUCT NAME, MODEL AND SPECIFICATION Relay
T92 series Contact load: NO:30A 277VAC/30VDC; CO:30A 277VAC/30VDC(NO), 3A 277VAC/30VDC(NC); NO:30A 250VAC(X contact series); 线圈: 12VAC、24VAC、48VAC、110VAC、110VAC/120VAC、208VAC、220VAC/240VAC、250VAC/277VAC ;3.5VA/ 4.0VA ;Electrical endurance: 20000 cycles(277VAC),10000 cycles(30VDC),100000 cycles (30A 250VAC/X contact series); Mechanical endurance:200000 cycles; Ambient temperature:-40°C ~ 65°C,-40°C ~ 25°C(X contact series); RTⅡ, RTⅢ see series description in annex

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS GB/T 21711.1-2023

TYPE OF CERTIFICATION SCHEMES Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462155-2010.

Date of original issued: Jun.15,2016

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGNATURE:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE



CHINA QUALITY CERTIFICATION CENTRE CO., LTD.
Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86 10 83886666
<http://www.cqc.com.cn>



CERTIFICATE OF PRODUCT CERTIFICATION

APPENDIX

Page 1 of 1

CERTIFICATE NO.: CQC16002142753

PAPER:

型号命名方法:

T92	*	*	*	*	*	..*	*****
代码: 6位数字或字母代码(产品上可不表示出来)							
线圈电压: 12:12VAC; 24:24VAC; 48:48VAC; 110:110VAC; 120:110VAC/120VAC; 208:208VAC; 240:220VAC/240VAC; 277:250VAC/277VAC							
触点材质: 2: AgCdO; 4: AgSnO X: AgNi(可动触点)+AgSnOInO(固定触点)							
安装方式: 1: PCB 安装, 焊接端子; 2: 经由凸缘面板安装, 250**0.32"快接端子; 3: 经由凸缘面板安装, 187**0.32"为线圈快接端子, 250"为触点快接端子; 4: 经由凸缘面板安装, 187**0.20"为线圈快接端子, 250"为触点快接端子; 5: 经由凸缘面板安装, M4 螺丝端子, 仅适用于外壳类型为 P 及触点结构为 7 的结构							
线圈类型: A: 交流线圈 60Hz 或 50/60Hz; F: 交流线圈 50Hz							
触点结构: 7: 双刀单掷-常开型; 11: 双刀双掷-转换型							
外壳类型: P: 外壳带气孔不密封; S: 外壳气孔密封							
产品基本型号: T92							

NOTE: This appendix is valid when used with the certificate.



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE