CERTIFICATION REPORT



Moncton Montréal Toronto Winnipeg Edmonton Vancouver Brussels Taiwan Hong Kong

REPORT NO: LR 7189A-399

Edition 1: July 14, 1993; Application No LR 7189A-399 - Rexdale

Issued by N. Sajatovich

Contents: Pages - 1 to 4

Figures - 1 to 2

Attachments - 1 to 3 (Engineering Report Only)

SUBJECT

CLASS 4414 04 - GROUNDING AND BONDING DEVICES

Grounding and bonding connectors, copper taps, Part No 80408-2 and 80408-4.

REPLACES

Page No:

Page Date:

Application No:

REPORT NO: LR 7189A-399

Page No: 2

Date Issued: July 14, 1993 Application No: LR 7189A-399

Issued By: N. Sajatovich

APPLICABLE REQUIREMENTS

CSA Std C22.2 No.

41-M1987 - Grounding and Bonding Equipment

MARKINGS

On each connector body: (1)(2)(3)(7)

On or in the smallest unit package: (4)(5)(6)

- (1) Manufacturer's name or trademark.
- (2) CSA Mark.
- (3) Wire sizes.
- (4) Wire combinations.
- (5) Electrode size.
- (6) Part number.
- (7) The wording, "DIRECT BURIAL", "DB" or equivalent.

ALTERATIONS

As indicated in "MARKINGS" above.

FACTORY TESTS

Not applicable.

DESCRIPTION

Grounding and bonding connectors, "SHEAR-LOK" copper taps, Part No 80408-2 and 80408-4, for direct burial applications, copper conductors only.

The wire combinations for each Part No are as follows:

Part No	Large Wire	Small Wire
80408-2	5/8 Galv rod (.625)	6 SOL, STR
80408-4	3/4 Galv rod (.750)	6 SOL, STR

- Body: Copper alloy, CDA 954 with factory applied anti-oxidation compound, C-shaped, 1.73 in wide and 2.40 in long. Refer to Figs 1 and 2.
- 2. <u>Wedge</u>: Copper alloy, CDA 954 and similar in shape to presently Certified C-Lok wedge. Refer to Figs 1 and 2 for dimensions and shape.
- Bolt: Silicone bronze, CDA 651. The bolt head is designated to shear at a pre-determined torque. Hex bolt is approx 2.87 in long, 5/16-18 and supplied with a stainless steel washer.