

CSA ✓

# Canadian Standards Association REPORT

LABORATORY 178 REXDALE BLVD., REXDALE, ONTARIO	REPORT No. LR 16455-71
DATE July 27, 1982	GUIDE No. 365-E-1
SUBMITTOR Amp Inc., P.O. Box 3608, Harrisburg, PA 17105  Attention: Mr. T. Rudolph	APPLICABLE REQUIREMENTS CSA Std. C22.2 No 0 42-1959
EQUIPMENT Bifurcated leaf connectors Series 640XXX with prefixes and suffixes for use with Nos 30 to 18 AWG wire, 250V.	
MARKINGS The submittor's name or trademark, the CSA Monogram and the electrical rating moulded or die-stamped on each connector. The catalogue number on the connector or on the containing carton.  It is the Submitter's responsibility to ensure that the CSA Mark is only applied to this equipment when it complies with the "Applicable Requirements"	
ALTERATIONS None.	
FACTORY TEST None.	

This equipment, when incorporating the "Alterations" described (if any), complies with the "Applicable Requirements".

Report by: E. Simpson,  
Reviewed by: W.F. Fromm, P. Eng.,  
Wiring Systems Section,  
Certification Division.

FS/jp