File E28476

Vol. 4 Sec. 60 Vol. 20 Sec. 4 Vol. 26 Sec. 9 Vol. 39 Sec. 20

Vol. 41 Sec. 8

and Report

## DESCRIPTION

Page 1

Issued: 1-26-78

Revised: 1-12-00

## PRODUCT COVERED:

AMP Shunt Connectors, see illustrations for catalog numbers.

## **GENERAL:**

These devices are multipole connectors employing jumpers or contacts for use with printed wiring boards.

## ENGINEERING CONSIDERATIONS (NOT FOR UL REPRESENTATIVE USE):

 $\underline{\text{Use}}$  - For use only in complete equipment where the acceptability of the combination is determined by Underwriters Laboratories.

Conditions of Acceptability - In order to be judged acceptable as a component of electrical equipment, the following conditions should be met.

- 1. These devices should be used only where they will not interrupt the current.
  - 2. These devices have not been tested for current-carrying capability.
- 3. The suitability of the mounting means shall be determined in the end use.
- 4. The placement of these devices within the appliance enclosure should be such that spacings between the live part and the appliance are suitable for the particular application.
- 5. The adjacent poles may carry current at potentials not exceeding 250 V between any two circuits.
- 6. The electrical and mechanical contact between the connector and the printed wiring board are to be judged.

\* 7. The electrical and mechanical suitability of the wiring terminals shall be determined in the end use.

RLS MEL\64377

File E28476	Vol. 4	Sec. 60	Page 1A	Issued:	1978-01-26
	Vol. 20	Sec. 4		Revised:	2007-11-16
	Vol. 26	Sec. 9			
	Vol. 39	Sec. 20			
	Vol. 41	Sec. 8			
		and Report			

- 8. The suitability of the spacings between adjacent poles and the associated voltage rating shall be determined in the end-use. Dielectric testing has not been performed.
- 9. The suitability of the insulating materials used in the molded bodies shall be judged in the end-use equipment.
- 10. The operating temperature of these devices should not exceed the temperature ratings of the insulating materials. These materials may be used interchangeably at a maximum temperature of 65°C.
- 11. The flame class rating of the insulating materials used in the connector housing for model 84481 has not been evaluated.